

Missouri Department of Natural Resources



PUBLIC NOTICE

DRAFT MISSOURI STATE OPERATING PERMIT

DATE: August 13, 2004

In accordance with the state Clean Water Law, Chapter 644, RSMo, Clean Water Commission regulation 10 CSR 20-6.010, and the federal Clean Water Act, the applicants listed herein have applied for authorization to either discharge to waters of the state or to operate a no-discharge wastewater treatment facility. The proposed permits for these operations are consistent with applicable water quality standards, effluent standards and/or treatment requirements or suitable timetables to meet these requirements (see 10 CSR 20-7.015 and 7.031). All permits will be issued for a period of five years, unless noted otherwise in the Public Notice for that discharge.

On the basis of preliminary staff review and the application of applicable standards and regulations, the Missouri Department of Natural Resources (MDNR), as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions. The proposed determinations are tentative pending public comment.

Persons wishing to comment on the proposed permit conditions are invited to submit them in writing to the Department of Natural Resources, Water Protection Program, P.O. Box 176, Jefferson City, Missouri 65102, ATTN: Peter Goode, Professional Engineer. Please include the permit number in all comment letters.

Comments should be confined to the issues relating to the proposed action and permit(s) and the effect on water quality. The MDNR may not consider as relevant comments or objections to a permit based on issues outside the authority of the Clean Water Commission, (see Curd v. Mo. Clean Water Commission, 586 S.W.2d 58 Mo. App. 1979).

All comments must be postmarked by September 13, 2004 or received in our office by 5:00 p.m. on September 16, 2004. The requirement of a signed document makes it impossible to accept email comments for consideration at this time. Comments will be considered in the formulation of all final determinations regarding the applications. If response to this notice indicates significant public interest, a public meeting or hearing may be held after due notice for the purpose of receiving public comment on the proposed permit or determination. Public hearings and/or issuance of the permit will be conducted or processed according to 10 CSR 20-6.020.

Copies of all draft permits and other information including copies of applicable regulations are available for inspection and copying at DNR's website, <http://www.dnr.state.mo.us/wpscd/wpcp/homewpcp.htm>, or at the Department of Natural Resources, Water Protection Program, 205 Jefferson Street, P.O. Box 176, Jefferson City, Missouri 65102, between the hours of 8:00 a.m. and 5:00 p.m., Monday through Friday.

Public Notice Date: August 13, 2004

Permit Number: MO-0115517

Northeast Regional Office

FACILITY NAME AND ADDRESS	NAME AND ADDRESS OF OWNER
Cargill Turkey Products 1001 East Smith Street California, MO 65018	Cargill Inc. 1001 East Smith Street California, MO 65018
RECEIVING STREAM & LEGAL DESCRIPTION	TYPE OF DISCHARGE
Unnamed Tributary to E. Brush Creek, E. Brush Creek, Sec. 27, T45N, R15W, Moniteau County	Industrial, reissuance

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION

MISSOURI CLEAN WATER PERMIT

In compliance with the Missouri Clean Water Law (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500 and Congress) as amended,

Permit No.: MO-0115517

Owner: Cargill, Inc.
Address: 1001 East Smith Street, California, MO 65018

Continuing Authority: Cargill, Inc.
Address: 1001 East Smith Street, California, MO 65018

Facility Name: Cargill Turkey Products
Address: 1001 East Smith Street, California, MO 65018

Legal Description: NE ¼, Sec. 27, T45N, R15W, Moniteau County

Receiving Stream: Unnamed Tributary to East Brush Creek (U)
First Classified Stream and ID: East Brush Creek (C) 303(d) 00811
USGS Basin & Sub-watershed No.: (10300102-160002)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

Outfall #001 - Poultry Processing - SIC #2015

Storm water runoff from processing areas, treated in impoundment with chlorination. Design flow is 0.046 MGD. Actual flow is dependent on rainfall.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

Effective Date

Stephen M. Mahfood, Director, Department of Natural Resources
Executive Secretary, Clean Water Commission

Expiration Date
MO 780-0041 (10-93)

Jim Hull, Director of Staff, Clean Water Commission

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS				PAGE NUMBER 2 of 5		
				PERMIT NUMBER MO-0115517		
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #001</u>						
Flow	MGD	*		*	once/quarter	24 hr. estimate
Biochemical Oxygen Demand ₅	mg/L	*		*	once/quarter****	grab**
Chemical Oxygen Demand	mg/L			*	once/quarter****	grab
Total Suspended Solids	mg/L	*		*	once/quarter****	grab
Settleable Solids	mg/L/hr	*		*	once/quarter****	grab
pH - Units	SU	***		***	once/quarter****	grab
Fecal Coliform	#/100mL	1,000		400	once/quarter****	grab
Oil & Grease	mg/L	15		10	once/quarter****	grab
Total Residual Chlorine (Note 1)	mg/L	1.0		1.0	once/quarter****	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
B. STANDARD CONDITIONS						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Part I</u> STANDARD CONDITIONS DATED <u>October 1, 1980</u> and <u>August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

MO 780-0010 (8/91)

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

* Monitoring requirement only.

** A grab sample shall be taken during a storm event of 0.1" or greater and during the first thirty minutes of the discharge (or as soon thereafter as practical).

*** pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0-9.0 pH units.

**** Sample once per quarter in the months of February, May, August, and November.

Note 1 - Please note that your permit has a limit on Total Residual Chlorine. You must use an analytical method that has a detection level of at least 0.1 mg/L.

C. SPECIAL CONDITIONS

1. This permit may be modified, or alternatively revoked and reissued, to comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C), and (D), 304(b)(2) and 307(a)(2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:

- (a) Contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
- (b) Controls any pollutant not limited in the permit.

The permit as modified or reissued under the above paragraphs shall also contain any other requirements of the Act then applicable.

2. All outfalls must be clearly marked in the waterway.
3. Permittee will cease discharge of effluent to areawide wastewater treatment system within 90 days of notice of its availability.
4. This permit may be reopened, modified or alternatively revoked and reissued, to incorporate new or modified effluent limitations or other conditions, if the result of a wasteload allocation study, toxicity test, or other information indicates changes are necessary to ensure compliance with Missouri's Water Quality Standards.
5. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
 - (1) One hundred micrograms per liter (100 ug/L);
 - (2) Two hundred micrograms per liter (200 ug/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 ug/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
 - (4) The level established in Part A of the permit by the Director.
- (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.

6. Report as no-discharge when a discharge does not occur during the report period.
7. General Criteria. The following water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
 - (a) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
 - (b) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - (c) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
 - (d) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
 - (e) There shall be no significant human health hazard from incidental contact with the water;

C. SPECIAL CONDITIONS (continued)

7. General Criteria. (continued)

- (f) There shall be no acute toxicity to livestock or wildlife watering;
 - (g) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
 - (h) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.
8. The discharge of storm water from these facilities shall not cause a violation of the state water quality standards, 10 CSR 7.01, which states, in part, that no water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following criteria:
- a. Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
 - b. Waters shall be free from scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - c. Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses.
 - d. Waters shall be free from substances or conditions in sufficient amounts to have a harmful effect on human, animal or aquatic life.
9. All paint solvents, petroleum products and petroleum waste products (except fuels), and storage containers (such as drums, cans or cartons) shall be stored so that these materials are not exposed to storm water. Spill prevention, control, and/or management shall be provided sufficient to prevent any spills of these pollutants from entering a water of the state. Any containment system used to implement this requirement shall be constructed of materials compatible with the substances contained and shall also prevent the contamination of groundwater.
10. Collection facilities shall be provided on-site, and arrangement made for proper disposal of waste products, including but not limited to, petroleum waste products and solvents.
11. Good housekeeping practices shall be maintained on the site to keep solid waste from entry into waters of the state.
12. All fueling facilities present on the site shall adhere to applicable federal and state regulations concerning underground storage, above ground storage, and dispensers, including spill prevention, control and counter measures.
13. Substances regulated by federal law under the Resource conservation and Recovery Act (RCRA) or the Comprehensive Environmental Response, Compensation and Liability Act (CERCLA) that are transported, stored, or used for maintenance, cleaning or repair shall be managed according to the provision of RCRA and CERCLA.
14. An individual shall be designated by the permittee as responsible for environmental matters. Staff on the permitted facility shall inspect, on workdays, any structures that function to prevent pollution of storm water or to remove pollutants from storm water and of the facility in general to ensure that any Best Management Practices are continually implemented and effective.
15. All involved personnel shall be trained in material handling and storage, and housekeeping of maintenance areas. Upon request, proof of training shall be submitted to the Department.

D. SCHEDULE OF COMPLIANCE

1. By December 31, 2004, permittee shall create and implement a Storm Water Pollution Prevention Plan (SWPPP) for all areas of the plant that contribute to Outfall #001.
2. In January, 2007, the permittee shall submit a report to the Water Protection Program's, Water Pollution Branch, NPDES Permits and Engineering Section, detailing the SWPPP has been effective in controlling storm water pollution.

DRAFT

Date of Fact Sheet: August 4, 2004

Date of Public Notice: August 13, 2004

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) PERMIT
FACT SHEET

This Fact Sheet explains the applicable regulations, rationale for development of this permit and the public participation process.

NPDES PERMIT NUMBER: MO-0115507

FACILITY NAME: Cargill Turkey Products

OWNER NAME: Cargill, Inc.

LOCATION: Sec. 27, T45N, R15W

County: Moniteau

RECEIVING STREAM: Unnamed Tributary to East Brush Creek

FACILITY CONTACT PERSON: Darryl Englehardt

TELEPHONE: (573) 796-7141

FACILITY DESCRIPTION AND RATIONALE

The monitoring requirements in this permit are being changed to conform to other meat processing plants in Missouri. This permit has a fecal coliform limit because the creek that is discharged to flows through the City of California. The permit also contains a 1.0 Total Residual Chlorine limit.

This permit will be issued for a period of five years.

